

Perez, Benito (DDOT)

From: Kelly, Alice (DDOT)
Sent: Wednesday, January 30, 2013 2:57 PM
To: Perez, Benito (DDOT)
Subject: FW: Vending regulations

Fyi FEMS comment

Alice Kelly
202-671-2252

From: Gil, Helder (DCRA)
Sent: Wednesday, January 30, 2013 2:37 PM
To: Kelly, Alice (DDOT)
Subject: FW: Vending regulations

Helder Gil, Esq.
Legislative & Public Affairs Officer
Department of Consumer and Regulatory Affairs
1100 Fourth Street, SW
Washington, D.C. 20024
Phone: (202) 442-8945
Twitter: @dcra
Website: dcra.dc.gov

Save the date!

Mayor Gray's 2013 State of the District Address is Tuesday, February 5th at 7:00 pm at the Sixth and I Historic Synagogue.

Attend in person, watch on [DCN](#), or follow on Twitter via [@mayorvincegray](#).

From: Faust, Bruce (FEMS)
Sent: Friday, November 23, 2012 3:28 PM
To: Gil, Helder (DCRA)
Subject: Vending regulations

Good Afternoon Helder,

Seems like you and DDOT have your hands full with the proposed vending regs....

I was reviewing these today, and noticed what I believe to be an inconsistency.

DC law does not allow parking within 10' of a fire hydrant, yet we are going to allow vendors to set up within 5' according to the vending regs. This should not be allowed and the vending regs should be consistent at 10'. It is my

belief that 5' will not allow our firefighters enough room to connect hoses and appliances and room for the hoses to expand when charged with water.

Can this be changed at his point?

Thanks for the consideration. I have just found the time to review these.

Bruce D. Faust
Deputy Fire Chief
Fire Marshal
Washington DC Fire & EMS Department
1100 4th St SW Suite E700
Washington DC 20024
(202) 727-3298
(202) 345-7117

Help 9-1-1 Save Your Life!

Create a free Safety Profile to provide critical, lifesaving data to 9-1-1 in the event of an emergency call today at www.smart911.com.

Inform first responders in advance!